

Akce : STAVEBNI UPRAVY CASTI OBJEKTU c.p. 28, TLUSTICE  
Datum : 24. 7.2024

Teplota topne vody - privodni : 70.0 oC  
vratne : 55.0 oC  
Procento vykonu pro navrh teles : 100.0

Vypis pro okruh c. 1

Mistnost cislo popis	Soustava teplota oC oC/oC	Otopne teleso --	delka mm	vodni objem dm3	tepelny vykon W
101 ucebna	20 70/55	33-090090-60-VK	900	11.3	2377
101 ucebna	20 70/55	33-090090-60-VK	900	11.3	2377
101 ucebna	20 70/55	33-090080-60-VK	800	10.1	2113
102 ucebna	20 70/55	33-090090-60-VK	900	11.3	2377
102 ucebna	20 70/55	33-090090-60-VK	900	11.3	2377
102 ucebna	20 70/55	33-090090-60-VK	900	11.3	2377
102 ucebna	20 70/55	33-090090-60-VK	900	11.3	2377
103 chodba	15 70/55	21-060050-60-VK	500	2.9	598
104 vstupni hala	15 70/55	21-060050-50-KLASIK	500	2.9	598
105 WC	15 70/55	21-090080-60-VK	800	6.6	1300
107 kabinet	20 70/55	21-090110-60-VK	1100	9.1	1533

Otopne teleso --	vyska mm	delka mm	cena Kc/ks	Celkem pocet kusu	Celkem cena Kc	vodni objem dm3	tepelny vykon W
21-060050-50-KLASIK	600	500	0	1	0	2.9	597
21-060050-60-VK	600	500	0	1	0	2.9	597
21-090080-60-VK	900	800	0	1	0	6.6	1300
21-090110-60-VK	900	1100	0	1	0	9.1	1532
33-090080-60-VK	900	800	0	1	0	10.1	2113
33-090090-60-VK	900	900	0	6	0	68.0	14262
Celkem okruh c. 1				11	0	99.7	20401
Celkem objekt				11	0	99.7	20401